

96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: info@govmark.com

Page 1

Received: 12/05/2013 | Completed: 12/12/2013 | Letter: C4 CJ **P.O.**#: 17324 Test Report #: 2-99883-0-04 Client's Style: 20oz Vinyl Wallcovering with Non-Woven Backing. Content: Polycotton/Wood Pulp Non-woven Backing. Weight: **Identification** 20oz Linear Yd. Color: Sample ID #150336. (see continuation) Tested For: Mark Rain **Key Test:** FTM 5100.1/ASTM F793 Roysons Corp. 40 Vanderhoof Avenue **Tel:** 1-(973)-625-5570 Ext: 124 Rockaway, NJ 07866 **Fax:** 1-(973)-625-5917 CLIENT'S IDENTIFICATION (continuation): End Use of Fabric: Commercial Wallcovering. Category: Break/Tensile Specifier: ASTM F 793 PC: 24H TEST PERFORMED: Federal Test Standard 191A Method 5100.1 - Strength and Elongation, Breaking of Woven Cloth; Grab Method RESULTS: Machine Cross Machine Direction Direction Specimen # (lbs) (lbs) \_\_\_\_\_ 86 1 71 75 86 87 72 4 88 70 5 70 88 \_\_\_\_\_ \_\_\_\_\_ Avg 87 72 REMARKS: None.

CLASSIFICATION	CRITERIA:	As	cited	by	ASTM	F	793	Standard	Classification	of	Wallcovering	by	Durability
Characteristics	s, Commercia	1 8	Service	abi	lity		-						

		Machine Direction	Cross Machine Direction
Category	Type	(lbs)	(lbs)
IV	I	Minimum 40	Minimum 30
V	II	Minimum 50	Minimum 55
VI	III	Minimum 100	Minimum 95

CONCLUSION: Based on the above Results and Classification Criteria, the item tested:

For	Category	IV	Type	I:	[x]	Complies;	[	]	Does	not	comply
For	Category	V	Type	II:	[x]	Complies;	[	]	Does	not	comply
For	Category	VI	Type	III:	[_]	Complies:	ſx	1_	Does	not.	comply



96-D Allen Boulevard Farmingdale, New York 11735-5626 USA Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956 e-mail: info@govmark.com

Page 2 Received: 12/05/2013 | Completed: 12/12/2013 | Letter: C4 CJ **P.O.**#: 17324 2-99883-0-04 Test Report #: Client's Style: 20oz Vinyl Wallcovering with Non-Woven Backing. Content: Polycotton/Wood Pulp Non-woven Backing. Weight: **Identification** 20oz Linear Yd. Color: Sample ID #150336. (see continuation) Tested For: Mark Rain **Key Test:** FTM 5100.1/ASTM F793 135 Roysons Corp. 40 Vanderhoof Avenue **Tel:** 1-(973)-625-5570 Ext: 124 Rockaway, NJ 07866 Fax: 1-(973)-625-5917 CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by Federal Test Standard 191A Test Method 5100.1. JAN 2 4 2014 AUTHORIZED SIGNATURE THE GOVMARK ORGANIZATION, INC. / ec MS. PHYLLIS PETTIT (Page 1 of 1)